

COUNTY OF SUMMIT, OHIO

Ilene Shapiro, Executive

Department of Development, Building Standards Division · www.co.summit.oh.us
1030 East Tallmadge Avenue · Akron, Ohio 44310 · 330.630.7280 · fax 330.630.7296

December 22, 2020

Virtual Inspections are now required for furnace and hot water heater installations in existing residences. When the installer completes the project, take pictures of the areas listed below and email the photos to inspections@summitoh.net. Please include the permit number, address, your name and contact phone number in the body of the email. An inspector will review the photos and contact you with any questions and you will receive your inspection results via email.


Virtual Inspection Required Photos

- Furnace Inspections:**
1. Permit on jobsite
 2. Overall furnace
 3. Venting
 4. Gas valve and electrical disconnect
 5. Termination
 6. Chimney liner
 7. CO Detector
 8. Combustion Air Requirements

- Hot Water Tank:**
1. Permit on jobsite
 2. Overall Tank
 3. Venting
 4. Gas valve and electrical disconnect
 5. Termination
 6. CO Detector
 7. Expansion Tank
 8. Chimney liner
 9. Combustion Air Requirements

NOTE: If any clearances to combustibles are close please show measurements illustrating you meet minimum clearances.

Kindest regards,


Christopher Randles
Chief Building Official